

From: Water Master

To: Cedar Highlands HOA

Water Report 23 April through 20 May 2011

Current Status of the Water System

- Both water tanks are full and overflowing.
- Weekly samplings of Chlorine residuals for upper and lower systems were adequate.
- Two bacteria samples taken in May were negative for bacteria.
- Nitrate sample was taken in May awaiting results.

OTHER

Met on-site with John and Curtis from Ensine to go over items that still need to be completed by Precision and Curtis is to provide the list of the items to Landon.

The Chlorine analyzer was ordered and received and will be installed when things dry out.